Fire Door Inspection

Door-by-door fire door check: leaf, frame, gaps, seals, hinges, self-closer, signage and glazing.

Details

Site name *	
Site address	
Date *	_____ / _____ / _____
Time	_____ : _____
Inspector *	

Doors

Doors 1

Door reference / location *	
Fire rating	☐ FD30 ☐ FD60 ☐ FD90 ☐ FD120 ☐ Unknown
Door photo	*Attach photo or sketch*
Door leaf undamaged *	☐ Pass ☐ Fail ☐ N/A
Frame secure and undamaged *	☐ Pass ☐ Fail ☐ N/A
Gaps 2-4mm (max 10mm at threshold) *	☐ Pass ☐ Fail ☐ N/A
Intumescent strips and smoke seals intact *	☐ Pass ☐ Fail ☐ N/A
Minimum 3 hinges, secure, no missing screws *	☐ Pass ☐ Fail ☐ N/A
Self-closer closes door fully from any angle *	☐ Pass ☐ Fail ☐ N/A
Latch engages *	☐ Pass ☐ Fail ☐ N/A
Signage correct *	☐ Pass ☐ Fail ☐ N/A
Glazing intact and fire rated *	☐ Pass ☐ Fail ☐ N/A
Not wedged or held open *	☐ Pass ☐ Fail ☐ N/A
Door result *	☐ Pass ☐ Fail - repair ☐ Fail - replace

Remedial action	

Doors 2

Door reference / location *	
Fire rating	☐ FD30 ☐ FD60 ☐ FD90 ☐ FD120 ☐ Unknown
Door photo	*Attach photo or sketch*
Door leaf undamaged *	☐ Pass ☐ Fail ☐ N/A
Frame secure and undamaged *	☐ Pass ☐ Fail ☐ N/A
Gaps 2-4mm (max 10mm at threshold) *	☐ Pass ☐ Fail ☐ N/A
Intumescent strips and smoke seals intact *	☐ Pass ☐ Fail ☐ N/A
Minimum 3 hinges, secure, no missing screws *	☐ Pass ☐ Fail ☐ N/A
Self-closer closes door fully from any angle *	☐ Pass ☐ Fail ☐ N/A
Latch engages *	☐ Pass ☐ Fail ☐ N/A
Signage correct *	☐ Pass ☐ Fail ☐ N/A
Glazing intact and fire rated *	☐ Pass ☐ Fail ☐ N/A
Not wedged or held open *	☐ Pass ☐ Fail ☐ N/A
Door result *	☐ Pass ☐ Fail - repair ☐ Fail - replace
Remedial action	

Doors 3

Door reference / location *	
Fire rating	☐ FD30 ☐ FD60 ☐ FD90 ☐ FD120 ☐ Unknown

Door photo	*Attach photo or sketch*
Door leaf undamaged *	☐ Pass ☐ Fail ☐ N/A
Frame secure and undamaged *	☐ Pass ☐ Fail ☐ N/A
Gaps 2-4mm (max 10mm at threshold) *	☐ Pass ☐ Fail ☐ N/A
Intumescent strips and smoke seals intact *	☐ Pass ☐ Fail ☐ N/A
Minimum 3 hinges, secure, no missing screws *	☐ Pass ☐ Fail ☐ N/A
Self-closer closes door fully from any angle *	☐ Pass ☐ Fail ☐ N/A
Latch engages *	☐ Pass ☐ Fail ☐ N/A
Signage correct *	☐ Pass ☐ Fail ☐ N/A
Glazing intact and fire rated *	☐ Pass ☐ Fail ☐ N/A
Not wedged or held open *	☐ Pass ☐ Fail ☐ N/A
Door result *	☐ Pass ☐ Fail - repair ☐ Fail - replace
Remedial action	

Sign-off

Additional comments	
Inspector name *	
Inspector signature *	
Date signed *	_____ / _____ / _____

* Required